



## 5 year Fire Sprinkler Inspection, Testing, and Maintenance

Business Name: \_\_\_\_\_

Business Address: \_\_\_\_\_

Contact Number: \_\_\_\_\_ Date: \_\_\_\_\_

The following are the requirements Bullhead City Fire Department is requiring to complete a 5 year fire sprinkler inspection. This information is taken from NFPA 25 Table 5.1.

Yes    No    N/A

           1. **Inspection: Valves (all types);** follow Table 13.1.

Comments:

---



---



---

Yes    No    N/A

           2. **Inspection: Obstruction;** follow Section 14.2.2, also the inspection shall include removing and examining a minimum of three (3) fire sprinkler heads. One on a branch line near the riser, one on a branch line near the inspectors test, and one on a branch line in a remote area in the middle of the system looking for debris or anything that would impair the proper flow of water.

Comments:

---



---



---

Yes    No    N/A

           3. **Test: Gauges;** follow Section 5.3.2.

Comments:

---



---



---

Yes    No    N/A  
       

**4. Test: Sprinklers-extra high temperature;** follow section 5.3.1.1.1.3.

Comments:

---

---

---

Yes    No    N/A  
       

**5. Test: Sprinklers – fast response;** follow Section 5.3.1.1.1.2.

Comments:

---

---

Yes    No    N/A  
       

**6. Maintenance: Obstruction investigation;** follow Sections 13.2.1 and 13.2.2.

Comments:

---

---

---

Yes    No    N/A  
       

**7. Investigation: Obstruction;** follow Section 14.2.1, (the flushing connection can be the inspectors test valve).

Comments:

---

---

---

Yes    No    N/A  
       

**8. All annual requirements shall be completed.**

Comments:

---

---

---

Company Name, Address & Phone:

---

Signature

Date