Bullhead City Fire Department
2751 Laughlin Ranch Blvd.
Bullhead City, AZ 86429
928-758-3971
www.bullheadfire.org

Bullhead City Fire Department
5 year Fire Sprinkler Inspection, Testing, and Maintenance

Business Name: _____

Business Address: _____

Contact Number: _____ Date: _____

The following are the requirements Bullhead City Fire Department is requiring to complete a 5 year fire sprinkler inspection. This information is taken from NFPA 25 Table 5.1.

Yes No N/A

☐ ☐ ☐ 1. **Inspection: Valves (all types);** follow Table 13.1.

Comments:

_____

_____

_____

Yes No N/A

☐ ☐ ☐ 2. **Inspection: Obstruction**; follow Section 14.2.2, also the inspection shall include removing and examining a minimum of three (3) fire sprinkler heads. One on a branch line near the riser, one on a branch line near the inspectors test, and one on a branch line in a remote area in the middle of the system looking for debris or anything that would impair the proper flow of water.

Comments:

_____

_____

_____

Yes No N/A

☐ ☐ ☐ 3. **Test: Gauges;** follow Section 5.3.2.

Comments:

_____

_____

_____

Yes No N/A

☐ ☐ ☐ 4. **Test: Sprinklers-extra high temperature;** follow section 5.3.1.1.1.3.

Comments:

Yes No N/A

☐ ☐ ☐ 5. **Test: Sprinklers – fast response;** follow Section 5.3.1.1.1.2.

Comments:

Yes No N/A

☐ ☐ ☐ 6. **Maintenance: Obstruction investigation;** follow Sections 13.2.1 and 13.2.2.

Comments:

Yes No N/A

☐ ☐ ☐ 7. **Investigation: Obstruction;** follow Section 14.2.1, (the flushing connection can be the inspectors test valve).

Comments:

Yes No N/A

☐ ☐ ☐ 8. **All annual requirements shall be completed.**

Comments:

Company Name, Address & Phone:

Signature Date